

### ⚠ Important Safety Notice ⚠

It is the responsibility of the person installing the electrical equipment to ensure that the installation meets the requirements of the IET wiring regulations and is therefore 'fit for purpose'. Factors such as correct selection of components, cable sizing, protective devices and Earth bonding are all critical and should be checked prior to testing and power-up. Any other regulations applicable to the equipment being installed such as the Machinery Directive and current health and safety legislation must also be adhered to. Terminals, including factory fitted, should be checked periodically to ensure correct tightness.



<b>Main Switch</b>	
<b>British Standard</b>	BSEN 60947-3
<b>CE</b>	
<b>SEMKO Certified</b>	
<b>Rating</b>	100A 240V 50 Hz
<b>Number of Modules</b>	2
<b>Isolation</b>	Double Pole
<b>Category of Duty</b>	AC-22B
<b>Torque Settings</b>	2.5Nm
<b>Terminal Capacity</b>	35mm <sup>2</sup>
<b>22 x 58 Modular Fuse Holder</b>	
<b>Rating</b>	100A
<b>Single Module</b>	
<b>CE</b>	
<b>IP20 Rating</b>	
<b>Provision for Locking</b>	
<b>Torque Settings</b>	4Nm
<b>Terminal Capacity</b>	1.5-50mm <sup>2</sup> rigid / 35mm <sup>2</sup> multiple strand

