



MiniGrid Modular Switch Plates



Electrophoretically coated plates and back boxes provide a durable and long lasting heavy duty finish to the Metal Clad range of products.

Metal Clad switches are developed largely as a modular range based on the large selection of switch modules available in the CLICK MINIGRID Module range. Simple, single screw fixing of modules offers the simplest possible means of installing and replacing modules.

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

Telephone: 01827 63454

E-mail: sales@scolmore.com, technical@scolmore.com

Facsimile: 01827 63362



MiniGrid Modular Switch Plates (Unfurnished)

Product Range		
MiniGrid Modular Switch Plates (Unfurnished)		
CL401	1 Gang Plate Single Aperture	
CL402	1 Gang Plate Twin Aperture	
CL403	1 Gang Plate Triple Aperture	
CL404	2 Gang Plate (2+2) Aperture	
CL406	2 Gang Plate (3+3) Aperture	
CL426	2 Gang Plate 6 In-Line Aperture	







CL401



CL404





Errors & Omissions excluded. Specification is subject to change without notice. All Metal Clad modular switch plates are provided with 40mm deep back boxes.

V1.0

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB


Telephone: 01827 63454 **E-mail:** sales@scolmore.com, technical@scolmore.com


Facsimile: 01827 63362 Website: www.scolmore.com




MiniGrid Modular Switch Plates (Unfurnished)

Product Dimensional Drawings (mm)







Errors & Omissions excluded. Specification is subject to change without notice.

V1.0

Facsimile: 01827 63362

Website: www.scolmore.com

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB



MiniGrid Modular Switch Plates (Unfurnished)

6 MiniGrid Module Yoke



GR100PW






GR100PW CL518


Facsimile: 01827 63362



MiniGrid Modular Switch Plates (Unfurnished)

Product Dimensional Drawings (mm)





Errors & Omissions excluded. Specification is subject to change without notice.

V1.0

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

Telephone: 01827 63454 **E-mail:** sales@scolmore.com, technical@scolmore.com

Facsimile: 01827 63362



MiniGrid Modular Switch Plates (Unfurnished)

Technical Specification		
MiniGrid Modular Switch Plates (Unfurnished)		
Material Composition	Front Plate & Back Box: Electrophoretically Coated Steel	
	GR100 Mounting Yoke: Galvanised Steel	
	Insert: Urea	
	Earth Strap: Mild Steel	
	Earth Terminal: Brass	
Cable Size	Dependent on modules fitted	
Back Box Depth	40mm Provided	
Knockout Sizes	20mm	
Modular	Yes	
Warranty	10 Years	
IP Rating	IP20	
Operational Temperature	-5° to +40°C	
Standards	BS 5733 : 2010 + A1 : 2014	

Additional Information

Ensure that the mains supply is isolated before commencing installation and refer to the circuit diagram with the relevant product.

Bare earth cables must always be covered with appropriate sleeving and wired to the earth terminal.

CL512 requires (2x) GR100 MiniGrid Module Yokes.

CL518 requires (3x) GR100 MiniGrid Module Yokes.

Interchangeable with modules in the MiniGrid system.



Facsimile: 01827 63362





Scolmore International Ltd

1 Scolmore Park: Landsberg Lichfield Road Industrial Estate Tamworth, Staffordshire B79 7XB

t: 01827 63454

f: 01827 63362

w: www.scolmore.com

e: sales@scolmore.com

DECLARATION OF CONFORMITY

1. Issuer Name Scolmore International Limited

2. Issuer Address 1 Scolmore Park, Landsberg,

> Lichfield Road Industrial Estate. Tamworth, Staffordshire, B79 7XB

3. Object(s) of Declaration Metal Clad Range

> a. Group Modular Switch Plates (Unfurnished)

b. Model No. CL401, CL402, CL403, CL404, CL406, CL426, CL512, CL518

- 4. The object of the declaration described above is in conformity with the requirements of the following Legislations:
- 5. All products contained within the aforementioned comply with the relevant standards and requirements listed below.

BS 5733: 2010 + A1: 2014

6. I hereby declare that the equipment named above has been designed to comply with the relevant sections of the above referenced specifications. The unit complies with all applicable Essential Requirements of the Directives.

In conjunction with the above all manufacture and process controls are in accordance with ISO 9001:2008

Signed, for and on behalf of: Scolmore International Limited

Steven Bettson BSc - Senior Technical Support Engineer

CE 15







