



250V~ Neon Indicator Modules



GRIDPRO[®] offers a comprehensive range of modules in multiple finishes to offer ultimate flexibility. The GRIDPRO[®] range will complement your existing Click installation, as the range was specifically designed to seamlessly match our existing ranges of Click[®] accessories.

250V~ Neon Indicator Modules

Product Range

250V~ Neon Indicator Modules


GM2080**	Red Neon Indicator Module
GM2081**	Amber Neon Indicator Module
GM2082**	Green Neon Indicator Module



GM2080PW




GM2081BK




GM2082PW

250V~ Neon Indicator Modules

Product Dimensional Drawings (mm)



Wiring Diagram



Errors & Omissions excluded. Specification is subject to change without notice.

V1.0

250V~ Neon Indicator Modules

Technical Specification

250V~ Neon Indicator Modules

Material Composition	Indicator Lens: Polycarbonate / ABS Cover, Insert & Rear Housing: Nylon Terminals: Brass, Terminal Screws: Steel & Yellow Passivated
Voltage	250V~ 50Hz
Terminal Size	5mm ø
Torque Value	1.2Nm
Cable Size	2 x 4mm ² , 3 x 2.5mm ² or 1 x 6mm ²
Back Box Depth	25mm - 47mm (Deco, Deco+, Mode, Polar) 35mm - 47mm (Define, Definity)
Modular	Yes
Warranty	10 Years
IP Rating	IP20
Operational Temperature	-5° to +40°C
Standards	The Low Voltage Directive 2014/35/EU BS 5733: 2010

Additional Information

Ensure that the mains supply is isolated before commencing installation and refer to the circuit diagram supplied with the relevant product.

Bare earth cables must always be covered with appropriate sleeving and wired to the earth terminal.



EU DECLARATION OF CONFORMITY

1. *Issuer Name* Scolmore International Limited
2. *Issuer Address* 1 Scolmore Park, Landsberg,
Lichfield Road Industrial Estate,
Tamworth, Staffordshire, B79 7XB
3. *Object(s) of Declaration* GRID PRO Range
a. *Group* 250V~ Neon Indicator Module
b. *Model No.* GM2080, GM2081, GM2082
4. *The object of the declaration described above is in conformity with the requirements of the following Legislations:*
- | Document No | Title |
|-------------|-----------------------|
| 2014/35/EU | Low Voltage Directive |

5. *All products contained within the aforementioned comply with the relevant standards and requirements listed below.*

BS 5733: 2010

6. *I hereby declare that the equipment named above has been designed to comply with the relevant sections of the above referenced specifications. The unit complies with all applicable Essential Requirements of the Directives.*

In conjunction with the above all manufacture and process controls are in accordance with ISO 9001:2008.

This declaration has been issued under the sole responsibility of the manufacturer, signed at, for and on behalf of: Scolmore International Limited

R Turner

Ross Turner - Technical Support Engineer