







MINIGRID™ modules are fitted as standard into our moulded POLAR™ & MODE®, decorative DEFINITY™, DEFINE® DECO® and Metal Clad ranges. The MINIGRID™ modules are all easily and quickly exchanged or mounted onto unfurnished plates by means of a simple single screw fixing.

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

Telephone: 01827 63454 **E-mail:** sales@scolmore.com, technical@scolmore.com

Facsimile: 01827 63362 Website: www.scolmore.com





Product Range

Finish Comparison



Antique Brass (AB)



Polished Brass (BR)



Polished Chrome (CH)



Click White (WH)



Satin Chrome (SC)



Satin Brass (SB)



Black Nickel (BN)



Polar White (PW)



Pearl Nickel (PN)



Stainless Steel (SS)



Brushed Steel (BS)



Black (BK)

Facsimile: 01827 63362

Website: www.scolmore.com

Errors & Omissions excluded. Specification is subject to change without notice.

V1.0

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

Telephone: 01827 63454 **E-mail:** sales@scolmore.com, technical@scolmore.com





Product Range

13A Fused Connection Unit Modules

MD047##**


13A Fused Connection Unit Module



MD047PW

Product Dimensional Drawings (mm)

MD047



Errors & Omissions excluded. Specification is subject to change without notice. ## Denotes Insert Colour, ** Denotes Module Finish

V1.0

Facsimile: 01827 63362

Website: www.scolmore.com


Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

Telephone: 01827 63454 **E-mail:** sales@scolmore.com, technical@scolmore.com





Wiring Diagrams



Facsimile: 01827 63362

Website: www.scolmore.com





Technical Specification

13A Fused Connection Unit Modules

Material Composition Module Front: Urea or Urea + Stainless Steel Cover (Ingot)

Rear Housing: Nylon

Terminals: Brass

Terminal Screws: Steel & Yellow Passivated

Voltage 240V~ 50Hz

Current Rating 13A

Terminal Size 3.5mm ø
Torque Value 0.8Nm

Cable Size 4 x 1.5mm² or 2 x 2.5mm²

Back Box Depth 16mm - 47mm (Dependant on Mounting Plate Used)

Modular Yes

Warranty 10 Years

Anti Microbial Certified Yes (Non Ingot Switches Only)

IP Rating IP20

Operational Temperature -5° to +40°C

Standards The Low Voltage Directive 2006/95/EC

BS 5733:1995

Modified ISO 22196

Additional Information

Ensure that the mains supply is isolated before commencing installation.

Bare earth cables must always be covered with appropriate sleeving and wired to the earth terminal.

All white moulded accessories are manufactured using Urea Formaldehyde, which has similar inherent properties to antimicrobial additives that inhibit the growth of infectious diseases. All products were independently tested and achieved a 99.9% kill rate across all four types of the strains of bacteria - MRSA, E-Coli, Salmonella, and Klebsiella Pneumoniae.

Errors & Omissions excluded. Specification is subject to change without notice.

V1.0

Facsimile: 01827 63362

Website: www.scolmore.com

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

Telephone: 01827 63454 **E-mail:** sales@scolmore.com, technical@scolmore.com



Scolmore

Scolmore International Ltd

1 Scolmore Park: Landsberg Lichfield Road Industrial Estate Tamworth, Staffordshire B79 7XB

t: 01827 63454

f: 01827 63362

e: sales@scolmore.com

w: www.scolmore.com

DECLARATION OF CONFORMITY

1. Issuer Name Scolmore International Limited

Issuer Address
 Scolmore Park, Landsberg,

Lichfield Road Industrial Estate, Tamworth, Staffordshire, B79 7XB

3. Object(s) of Declaration MINIGRID Range

a. *Group* 13A Fused Connection Unit Modules

b. Model No. MD047

4. The object of the declaration described above is in conformity with the requirements of the following Legislations:

Document No Title

2006/95/EC Low Voltage Directive

5. All products contained within the aforementioned comply with the relevant standards and requirements listed below.

BS 5733: 1995

6. I hereby declare that the equipment named above has been designed to comply with the relevant sections of the above referenced specifications. The unit complies with all applicable Essential Requirements of the Directives.

In conjunction with the above all manufacture and process controls are in accordance with ISO 9001:2008

Signed, for and on behalf of: Scolmore International Limited

8Belto

Steven Bettson BSc - Senior Technical Support Engineer

CE13







